CERTIFICATE REGARDING SAFE DRINKING WATER & SANITARY CONDITION

Dispatch No. 37909 **Date:** 18/09/2026

Certified that an inspection team headed by Er. Guriqbal Singh SDE & Sahil Bansal JE from W/S & Sanitation Department Sub Division Sunam inspected Adarsh Sen. Sec. School, Gandhuan (Sangrur) on 18.09.2026 and found that Adarsh Sen. Sec. School, Gandhuan (Sangrur) has safe drinking water facilities for the students and members of the institution and is maintaining the hygienic sanitation condition in the school building & campus as per the norms and reports. This certificate is valid upto 31.03.2027

Sub Division Engineer
W/S and Sanitation Sub Div.
Sunam

REGIONAL WATER TESTING LAB, SANGRUR

DEPARTMENT OF WATER SUPPLY & SANITATION, Punjab
Prem Basti, D. C Office Road, Opposite to Punjab Gramin Bank, Sangrur
rwtlsangrur@gmail.com

To,

Principal
Adarsh Sen. Sec. School, Gandhuan (Sangrur)

No.: RWTL/SNG/2627/00473 Dated : 22/09/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. Adarsh /Gandhuan/2026/564 Dated: 18/09/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 18/09/2026. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Sangrur

D/A : Test Report

Authorized Signatory
For, Regional Water Testing Lab
Sangrur

REGIONAL WATER TESTING LAB, SANGRUR

DEPARTMENT OF WATER SUPPLY & SANITATION, Punjab
Prem Basti, D. C Office Road, Opposite to Punjab Gramin Bank, Sangrur
rwtlsangrur@gmail.com

TC-17848

TEST REPORT

Name & Address of Customer : Principal Adarsh Sen. Sec. School, Gandhuan (Sangrur)		Customer Reference No.	No : Adarsh /Gandhuan/2026/564 Dated : 18/09/2026
		Sample Submitted by	Praveen Kumar
		Date of Sample Receipt	18/09/2026
		Analysis Starting Date	18/09/2026
		Analysis completion Date	22/09/2026
Discipline : Chemical Testing,Bacteriological Testing		Group: Water	
ULR No.:	TC179482600000240F	Sample Type :	Water
Test Report No.:	RWTL/SNG/2627/00473	Date of Issue :	22/09/2026
Registration no.:	RWTL/SNG/REG2627/02629	Condition of Sample :	Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Autoclavable Glass Bottle
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	NA / 350 ft
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	Sangrur
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.57	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	2	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	AGREEABLE	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	TDS	348	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
5	Turbidity	0.75	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
6	T. Alkalinity(CaCO3)	280	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
7	T. Hardness(CaCO3)	188	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
8	Calcium(Ca)	32	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
9	Magnesium(Mg)	26	30	100	mg/l	APHA (24th Ed 2023) Method: 3500-Mg+2 B By Calculation Method
10	Chloride(Cl)	22	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method
11	Iron(Fe)	BDL	1.0	No Relaxation	mg/l	Spectrophotometric Method
12	Sulphate(SO4)	64	200	400	mg/l	Spectrophotometric Method
13	Fluoride(F)	0.59	1.0	1.5	mg/l	APHA 4500 F-(23rd Ed 2017)/IS-3025 (Part-60)

Continue on next page

Reviewed and Approved By

Dr. Ramesh Jhorar
Quality Manager
Authorized Signatory
For,Regional Water Testing Lab
Sangrur

REGIONAL WATER TESTING LAB, SANGRUR

Prem Basti, D. C Office Road, Opposite to Punjab Gramin Bank, Sangrur
rwtlsangrur@gmail.com

14	Nitrate(NO3)	12	45	No Relaxation	mg/l	Spectrophotometric Method/ APHA 4500 NO3- (23rd Ed. 2017)
15	Arsenic(As)	BDL(0.005)	0.01	No relaxation	mg/l	Spectrophotometric Method/ Colorimetric Method
16	Total Coliform(TC)	Absent	Shall not be detectable in any 100 ml sample	No relaxation	---	IS 15185 Membrane Filtration Method
17	E-Coli	Absent	Shall not be detectable in any 100 ml sample	No relaxation	---	IS 15185 Membrane Filtration Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't beused be as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = mill gram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Dr. Ramesh Jhorar
Quality Manager
Authorized Signatory
For,Regional Water Testing Lab
Sangrur

End of the Test Report